

**Wildrose Farm and Garden Centre**

**June 14 th, 2021**

**750 Tin Can Alley**

**Gabriola , BC**

**I performed an flow rate test on the above property on April 28 th, 2021 to determine the current water yield from a well onsite.**

**The well was pumped for 4 hours (240 minutes) and the flow of water was measured periodically throughout the test. The test started at 4.0 imperial gallons per minute and was reduced with time to the final flow rate of 2.4 imperial gallons per minute. The well had stabilized at this pumping rate and maintained a constant flow rate at the above mentioned 2.4 imperial gallons per minute.**

**The original drill log stated the well yield at 2.0 gallons per minute, at the time of testing the flow rate was 2.4 imperial gallons per minute.**

**Brian Stachan**

**Gabriola Waterworks**

**Registration No: WPI 06041201**