

**From:** Squamish Connect <do-not-reply@squamishconnect.com>  
**Sent:** Tuesday, March 8, 2022 3:03 AM  
**To:** Becky McErlean  
**Subject:** [Squamish Connect] 1 Update

## 1 comment on things you're watching

### New Comment

#### Andrew Latimer (Squamish Nation) posted a comment

---

*Hello, the Squamish Nation has reviewed your file and has the following recommendations.*

*-Recommend language addressing archaeological concerns incorporated into the bylaw, specifically that should ground disturbance through construction or maintenance be planned in the shoreline zone, an archaeological assessment will be required.*

*- Recommend stronger language for letter "l" in Guidelines for the Construction and Replacement of Docks and Ramps around dock construction near eelgrass and kelp beds. Any new docks should not be implemented within 8 meters of an established eelgrass bed, or within 4 meters of an established kelp bed.*

*- Recommend stronger language for letter "t" in Guidelines for the Construction and Replacement of Docks and Ramps. Mooring buoys must be seagrass friendly to prevent scouring on the sea floor, and must include buoys with a mid-line float so as to prevent unnecessary damage to eelgrass habitat*

*Also, can you provide rationale around the proposed amendment to change the coastal setback of buildings from 15 meters to 7.5 meters? We see that it is only 15 meters for 2 lots. With the present-day increasing frequency and intensity of storms, coastal erosion, and sea level rise, we would recommend considering the original proposed set back of 15 meters.*

*Please let us know if you have any questions.*

---

PROJECT NAME

**Keats Shoreline Protection Project**

ISSUING AGENCY FILE NUMBER(S)

**6500-20 Keats Shoreline Protection Project**

REFERRAL ID

**500**

---

[View this Submission](#)